## **Executive Summary**

Objective

To assess the results of tests to BS 476:Part 6:1989+A1: 2009 and BS 476:Part 7:1997, obtained on specimens of the following product and to provide an opinion of compliance with the requirements for a Class 0 surface, as defined in Approved Document B to the Building Regulations 2000.

Generic Description	Product reference	Thickness / Weight per application area or density rate	unit	
Coated reinforced polyvinyl	"PVC Coated glass fibre	250-300 250-300g/m <sup>2</sup>		
chloride (PVC)	fabric"	micron		
Individual components used to manufacture composite:				
Coating product	"PVC"	70 micron Unable to provide	Э	
Scrim	"e-glass fiberglass fabric 5430"	170 micron 150g/m <sup>2</sup>		
Adhesive	Unable to provide	6g/m <sup>2</sup> Not stated		
Please see page 5 of this test report for the full description of the product tested				

**Test Sponsor** 

G.L.V. International (1995) Ltd, Maalot Industrial Area, 24952, Israel.

Opinion:

We consider the results of the tests to BS 476:Part 6:1989+A1: 2009 and BS 476:Part 7: 1997, demonstrate that the product, as tested, complies with the requirements for Class 0, as defined in paragraph A13(b) of Approved Document

B, 'Fire Safety', to the Building Regulations 2000.

**Date of Test** 

15<sup>th</sup>, 20<sup>th</sup> & 21<sup>st</sup> February 2013

## **Signatories**

C Meer	m Dele
Responsible Officer	Authorised
C. Meachin *	M. Dale *
Acting Testing Officer	Deputy Operations Manager

Report Issued: 21st March 2013

This version of the report has been produced from a .pdf format electronic file that has been provided by Exova Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Exova Warringtonfire

Document No.:

326052 & 326053

Page No.:

2 of 7

Author:

C. Meachin

Issue Date:

21st March 2013

Client:

G.L.V. International (1995)

Issue No.:

1

<sup>\*</sup> For and on behalf of Exova Warringtonfire.